

Stage 1 Disinfection Byproducts (Stage 1 DBPs):

**In "Your Water" column, for Stage 1 DBP compliance data, record the system-wide running annual average (RAA).

**The range should be the lowest to highest results of all compliance samples.

** If an MCL violation occurred, include a discussion of the MCL violation, including health effects language, below the appropriate table.

**** Stage 1 DBPs –**

- Total Trihalomethane monitoring under Stage 1 DBPR.
- TTHM MCL: 0.080 ppm
- MCL in CCR units: 80 ppb

Example: 2014 Results:

Total Trihalomethane Monitoring Results* (in ppb)	1st quarter	2nd quarter	3rd quarter	4th quarter
	2014	2014	2014	2014
Site - B01	31	45	68	40
Site - B02	35	44	67	41
Site - B03	35	45	73	40
Site - B04	33	48	67	41
Site - B05	34	44	71	37
Site - B06	30	47	68	40
Site - B07	35	46	69	42
Site - B08	32	44	65	38
System-wide Quarterly Average				
System-wide Running Annual Average*				

*Reported RAA for quarters 1-3 are based on results from previous quarters not reported on this table.

**Note: Gray highlighted numbers in the table above represent the range and the system-wide RAA of the results obtained during the calendar year.
**Also, since the 3rd quarter

****Stage 2 Disinfection**

**In "Your Water" column, record the highest locational running annual average (LRAA).

**For each monitoring location, report the range (lowest to highest results) of all compliance samples.

** If an MCL violation occurred, include a discussion of the MCL violation, including health effects language, below the appropriate table. System

**** Stage 2 DBPs**

- Total Trihalomethane monitoring under Stage 2 DBPR
- TTHM MCL: 0.080 ppm
- MCL in CCR units: 80 ppb



Table VIII Stage 2 Disinfection

Disinfection Byproduct	Year	MCL Y/N	Your Water (highest)	Range Low	MCLG	MCL	Likely Source of Contamination
TTHM (ppb)			52		N/A	80	Byproduct of drinking water disinfection
Location B01	2015	N		31-68	N/A	80	
Location B02	2015	N		35-67	N/A	80	
Location B03	2015	N		35-73	N/A	80	
Location B04	2015	N		33-67	N/A	80	
Location B05	2015	N		34-71	N/A	80	
Location B06	2015	N		30-68	N/A	80	
Location B07	2015	N		35-69	N/A	80	
Location B08	2015	N		32-65	N/A	80	
HAA5 (ppb)			32		N/A	60	Byproduct of drinking water disinfection
Location B01	2015	N		18-31	N/A	60	
Location B02	2015	N		19-33	N/A	60	
Location B03	2015	N		19-31	N/A	60	
Location B04	2015	N		19-35	N/A	60	
Location B05	2015	N		18-28	N/A	60	
Location B06	2015	N		20-28	N/A	60	
Location B07	2015	N		18-29	N/A	60	
Location B08	2015	N		18-33	N/A	60	